



COUNTY OF MENDOCINO
Executive Office
Facilities & Fleet Division

CARMEL J. ANGELO
CHIEF EXECUTIVE OFFICER

851 Low Gap Road
Ukiah, CA 95482

Email: facilities@mendocinocounty.org
Website: www.mendocinocounty.org

Office: (707) 234-6050
Fax: (707) 463-4673

ADDENDUM #: 1

PROJECT: Regional Behavioral Health Training Center - Flooring Project

DATE: 12/19/19

ISSUED BY: Doug Anderson

The additions, omissions, clarifications, and/or corrections herein shall be made part of the Contract plans and specifications and shall be included in the Scope of Work and proposals to be submitted. This Addendum modifies the original plans and specifications as described below.


INQUIRIES AND CLARIFICATIONS TO PROJECT PLANS AND SPECIFICATIONS

1. Q: Should we figure carpeting the stage platform's front base with carpet?

A: Once carpet has been removed from the stage, trim back plywood that overhangs the stage such that it is flush with the front of the stage's vertical face. Install contrasting nosing (compatible with carpet tile), Burke or equal and a 6" rubber base (Burke or equal) to the front of the stage base.

2. See attached Mandatory pre-bid walk through attendance sheet.

ADDITIONAL INFORMATION



Bidders are reminded that they shall complete the Addenda Acknowledgement in the Bid Form of their Specification Book (Section 00310-2). Failure to do so may result in disqualification of the submitted bid.

BID 54-19

[illegible]