



**COUNTY OF MENDOCINO**  
**Executive Office**  
Facilities & Fleet Division

**CARMEL J. ANGELO**  
**CHIEF EXECUTIVE OFFICER**

851 Low Gap Road  
Ukiah, CA 95482

Email: wesolowm@mendocinocounty.org  
Website: www.co.mendocino.ca.us

Office: (707) 234-6050  
Fax: (707) 463-4673

**ADDENDUM #: 01**

**PROJECT: CI 854 -DOT Video Security System Laytonville Yard**

**DATE: June 24, 2020**

**ISSUED BY: Walter Kolon**

*The additions, omissions, clarifications, and/or corrections herein shall be made part of the Contract plans and specifications and shall be included in the Scope of Work and proposals to be submitted. This Addendum modifies the original plans and specifications as described below.*

**INQUIRIES AND CLARIFICATIONS TO PROJECT PLANS AND SPECIFICATIONS**

1. Q: Does the NVR need its own dedicated circuit, does it need to be hooked into the emergency generator?

A: Provide a new duplex outlet for the NVR tied into an emergency generator circuit.

2. Q: Does the NVR need a network connection?

A: Yes. Provide a CAT 6 wire connection in conduit from the NVR to the router.

**ADDITIONAL INFORMATION**

Attached find pre-bid conference sign in.

*Bidders are reminded that they shall complete the Addenda Acknowledgement in the Bid Form of their Specification Book (Section 00310-2). Failure to do so may result in disqualification of the submitted bid.*