



**COUNTY OF MENDOCINO**  
**Executive Office**  
Facilities & Fleet Division

**CARMEL J. ANGELO**  
**CHIEF EXECUTIVE OFFICER**

841 Low Gap Road  
Ukiah, CA 95482-3734

Email: ceo@co.mendocino.ca.us  
Website: www.co.mendocino.ca.us

Office: (707) 234-6068  
Fax: (707) 463-4673

**ADDENDUM #:** 01  
**RFB #:** 06-17  
**PROJECT:** Fort Bragg DOT Yard Material Bins Cover Project  
**DATE:** February 2, 2017  
**ISSUED BY:** Doug Anderson

*The additions, omissions, clarifications, and/or corrections herein shall be made part of the Contract plans and specifications and shall be included in the Scope of Work and proposals to be submitted. This Addendum modifies the original plans and specifications as described below.*

**INQUIRIES AND CLARIFICATIONS TO PROJECT PLANS AND SPECIFICATIONS**

1. **Q:** Structural Sheet S101 calls for "all steel deck/metal siding shall have a Kynar finish", whereas elevation drawings call for metal siding to be painted to match existing building. Shall the roof and wall panels be provided with Kynar finish, or field paint?  
**A:** Metal Wall Panels shall have a Kynar finish.

**ADDITIONAL INFORMATION**

*Bidders are reminded that they shall complete the Addenda Acknowledgement in the Bid Form of their Specification Book (Section 00310-2). Failure to do so may result in disqualification of the submitted bid.*